



Wheatland Tube
One Council Ave
Wheatland, PA 16161
724-342-6851

April 21, 2016

Re: Conformance to NSF 61 and California NSF/ANSI 61 Annex G, NSF/ANSI 372, AB 1953 "Lead-Free" Requirements

Wheatland Tube Company has achieved third party compliance through IAPMO R&T on its black and galvanized pipe. Wheatland's black and galvanized pipe listed below complies with NSF 61 NSF/ANSI 61 – Annex G, NSF/ANSI 372, AB 1953 "Lead-Free" Requirements and the State of California's legislation that requires any plumbing fitting or fixture used in a potable water application to have a maximum lead content of 0.25%.

Wheatland's ASTM A53 Standard Schedule 40 and Schedule 80 Black Pipe:

Wheatland's 1/8" through 4" A53 Type F Grade A BLACK Sch 40 and 80 pipe is NSF 61 certified.
Wheatland's 2" through 6" A53 Type E Grade B BLACK Sch 40 and 80 pipe is NSF 61 certified.

Wheatland's ASTM A53 Standard Schedule 40 and Schedule 80 Galvanized Pipe:

Wheatland's 1/8" through 4" A53 Type F Grade A GALVANIZED pipe is NSF 61 certified.
Wheatland's 2" through 6" A53 Type E grade B GALVANIZED pipe is NSF 61 certified.

Wheatland's certified pipe will have the "NSF 61" stenciled on the pipe to show compliance.

Wheatland's Water Well Casing, 2" through 6", both black and galvanized also conforms to the California NSF/ANSI 61 – Annex G, NSF/ANSI 372, AB 1953 "Lead- Free" Requirements.

Sincerely,

Michael S. Ryan
Technical Services Manager