

April 2, 2019

Re: Conformance to NSF 61 and California NSF/ANSI 61 Annex G, NSF/ANSI 372, AB 1953 “Lead-Free” Requirements

Wheatland Tube Company has achieved third party compliance through IAPMO R&T on its black and galvanized pipe. Wheatland’s black and galvanized pipe listed below complies with NSF 61 NSF/ANSI 61 – Annex G, NSF/ANSI 372, AB 1953 “Lead-Free” Requirements and the State of California’s legislation that requires any plumbing fitting or fixture used in a potable water application to have a maximum lead content of 0.25%.

Wheatland's ASTM A53 Standard Schedule 40 and Schedule 80 Black Pipe:

Wheatland’s 1/8" through 4" A53 Type F Grade A BLACK Sch 40 and 80 pipe is NSF 61 certified. Wheatland’s 2" through 6" A53 Type E Grade B BLACK Sch 40 and 80 pipe is NSF 61 certified.

Wheatland's ASTM A53 Standard Schedule 40 and Schedule 80 Galvanized Pipe:

Wheatland’s 1/8" through 4" A53 Type F Grade A GALVANIZED pipe is NSF 61 certified. Wheatland’s 2" through 6" A53 Type E grade B GALVANIZED pipe is NSF 61 certified.

Wheatland’s certified pipe will have the “NSF 61” stenciled on the pipe to show compliance, for sizes $\geq 1/2$ ".

Wheatland’s Water Well Casing, 2" through 6", both black and galvanized also conforms to the California NSF/ANSI 61 – Annex G, NSF/ANSI 372, AB 1953 “Lead-Free” Requirements.

Sincerely,



Michael S. Ryan
Technical Services Manager