Fire Sprinkler Pipe

WLS Schedule 30 Light Wall **Submittal Data Sheet**



FM Approved and Fully Listed Sprinkler Pipe

Wheatland's WLS steel fire sprinkler pipe is hot-dip galvanized to meet FM requirements for dry systems and is UL, C-UL and FM Listed.

Approvals and Specifications

The product meets or exceeds the following standards:

- ASTM: A795, Type F, Grade A
- ANSI/ASME B1.20.1 pipe threads
- NFPA 13

Manufacturing Protocols

WLS is subjected to the toughest possible testing protocols to assure the highest quality and long-lasting performance.

Finishes and Coatings

WLS is finished in black or hot-dip galvanized. All Wheatland black steel fire sprinkler pipe receives a proprietary mill coating to ensure a clean, corrosion-resistant surface that outperforms and outlasts standard lacquer coatings.

Product Marking

Each length of Wheatland fire sprinkler pipe is continuously stenciled to show the manufacturer, type of pipe, grade, size and length. Barcoding is acceptable as a supplementary identification method.

SPECIFICATIONS

NPS	NOM OD	NOM ID			UL CRR*		WLS		
		WLS	Schedule 10	Schedule 40	WLS	Schedule 40	Nominal wt./ft.	Pcs./ Lift 21'	Pcs./ Lift 25'
1	1.315	1.087	_	1.049	0.57	1.00	1.462	70	60
11⁄4	1.660	1.426	1.442	1.380	0.46	1.00	1.928	55	45
11/2	1.900	1.650	1.682	1.610	0.64	1.00	2.370	45	40
2	2.375	2.125	2.157	2.067	0.52	1.00	3.004	35	30

^{*} Calculated using Standard UL CRR formula, UL Fire Protection Directory, Category VIZY.







SUBMITTAL INFORMATION

PROJECT:	CONTRACTOR:	DATE:
ENGINEER:	SPECIFICATION REFERENCE:	SYSTEM TYPE:
LOCATIONS:	COMMENTS:	
BLACK	HOT-DIP GALVANIZED	



