

**INGREDIENTS LIST**  
**Living Building Challenge 4.0**

**CONTACT INFORMATION**

Dated: 01/2/2025

Name of Person Completing Form: Tiffany Dunworth  
 Company: Wheatland Tube Title: Technical Services Manager  
 Company Email: Tiffany.Dunworth@zekelman.com Telephone: 724-342-6851 x 8441

**MANUFACTURING FACILITY INFORMATION**

Company Name: Wheatland Tube Company  
 Address: One Council Avenue  
 Wheatland, Pennsylvania 16161 Country: USA  
 Website: www.wheatland.com Telephone: 724-342-6851

**PRODUCT INFORMATION**

Product Trade Name: Non-Galvanized Standard Steel Pipe and Sprinkler Pipe  
 Product Description / Type: 1/4" through 18" Non-Galvanized standard steel pipe & sprinkler pipe  
 Product Website (if applicable): www.wheatland.com  
 Volatile Organic Compounds (VOC) level (if wet-applied): N/A

We affirm Wheatland's Non-Galvanized Standard Steel Pipe and Sprinkler pipe do not contain any Living Building Challenge Red Listed Materials or Chemicals. Wheatland Tube Company can attest that the black coating does not contain any of the chemicals listed on LBC 4.0.

<b>PROPRIETARY INGREDIENTS</b>		
Proprietary Ingredients	0 % (Non-Galvanized Standard Steel Pipe and Sprinkler Pipe) of Total Product (by weight)	
<b>NON-PROPRIETARY INGREDIENTS LIST</b>		
<b>(Please list ingredients with chemical names or CAS #s so they can be vetted against the Red List)</b>		
Ingredient Name (chemical name)	CAS (Chemical Abstract Services) Number	% of Total Product (by weight)
Iron	7439-89-6	95.65
Aluminum	7429-90-5	0.070 Max
Carbon	7440-44-0	0.46 Max
*Chromium	7440-47-3	.10 Max
Copper	7440-50-8	0.21 Max
Manganese	7439-96-5	1.66 Max
Molybdenum	7439-98-7	0.25 Max
*Nickel	7440-02-0	0.10 Max
Silicon	7440-21-3	0.35 Max
Vanadium	7440-62-2	0.15 Max
Total Ingredient List =		100 %

\*Nickel and Chromium are residual elements in the steel we purchase and are not intentionally added.