



January 02, 2025

Reference: Sprinkler Piping Allowed for Pressures above 300 psi

Dear Valued Customer:

Wheatland Tube Company's working pressure ratings have increased for Schedule 10 and Schedule 40 steel sprinkler piping.

The affected piping includes:

- Wheatland's Schedule 10 ASTM A135 ERW Grade A – Sizes 1" through 4" – 500 psi.
- Wheatland's Schedule 10 ASTM A135 ERW Grade A – Sizes 5" and 6" – 400 psi.
- Wheatland's Schedule 10 ASTM A795 CW Grade A – Sizes 1 1/4" through 2 1/2" – 500 psi
- Wheatland's Schedule 40 ASTM A795 ERW Grade A – Sizes 1" through 2" – 500 psi
- Wheatland's Schedule 40 ASTM A53 ERW Grade B – Sizes 2" through 4" – 500 psi
- Wheatland's Schedule 40 ASTM A53 ERW Grade B – Sizes 5", 6" and 8" – 400 psi.
- Wheatland's Schedule 40 ASTM A53 CW Grade B (SureThread) - Sizes 1" thru 4" – 500 psi

The afore-mentioned information is offered to help installers understand the UL listed piping requirements and to assure the end-user that Wheatland pipe can handle the pressures above 300 psi.

However, Wheatland Tube does not offer any piping installation instructions or installation advice. This letter does not intend to override any local, state or federal codes or regulations that need to be complied with. A professional engineer, fire sprinkler consultant, or AHJ may still be required.

If I can be of any further assistance, please do not hesitate to contact me.

Sincerely,

Tiffany Dunworth
Technical Services Manager