



June 18, 2019

Reference: Sprinkler Piping Allowed for Pressures above 300 psi

To whom it may concern:

Wheatland Tube Company's Schedule 10 and Schedule 40 steel sprinkler piping can be used with any UL Listed and/or FM approved rubber gasketed fittings rated higher than 300 psi. All approved fittings that have been tested with Schedule 10 & Schedule 40 pipe to higher pressure ratings can be used with Wheatland's Sch 10 or Sch 40 pipe at that higher-pressure rating without additional testing.

The affected piping includes:

- Wheatland's Schedule 10 ASTM A135 ERW Grade A – Sizes 1" through 8"
- Wheatland's Schedule 40 ASTM A795 ERW Grade A – Sizes 1" through 2"
- Wheatland's Schedule 40 ASTM A53 ERW Grade B – Sizes 2" through 8"
- Wheatland's Schedule 40 ASTM A53 CW Grade A (SureThread) - Sizes 1" through 4"

The afore-mentioned information is offered to help installers understand the UL listed and FM Approved piping requirements and to assure the end-user that Wheatland pipe can handle the pressures above 300 psi.

However, Wheatland Tube does not offer any piping installation instructions. We do not offer installation advice. This letter does not intend to override any local, state or federal codes or regulations that need to be complied with. A professional engineer, fire sprinkler consultant, or AHJ may still be required.

If I can be of any further assistance, please do not hesitate to contact me.

Sincerely,

Michael S. Ryan  
Technical Services Manager  
Email: [mike.ryan@zekelman.com](mailto:mike.ryan@zekelman.com)