



**NEW SIZE: 1 NPS**


# HIGH QUALITY HIGH PERFORMANCE

**Get Schedule 10 Fire Sprinkler Pipe in All the Sizes You Need**

## Wheatland's Schedule 10

- ✓ 100% steel
- ✓ No special prep before painting
- ✓ Hot-dip galvanized or black finish
- ✓ ASTM A135, Type E, Grade A
- ✓ NFPA 13

Wheatland Tube's Schedule 10 sprinkler pipe consistently demonstrates superior performance. Our proprietary mill coating outlasts and outperforms standard lacquer-coated pipe, and our proprietary MIC SHIELD™ antimicrobial coating limits corrosion from microbes.



## SCHEDULE 10 WEIGHTS AND DIMENSIONS

	NPS	NOMINAL OD		NOMINAL ID		NOMINAL WALL		WT./FT.			WT./LIFT	WT./LIFT	WT./LIFT	UL
		in.	mm	in.	mm	in.	mm	lbs.	H <sub>2</sub> O FILLED lbs.	PCS./LIFT	21'	24'	25'	
<b>NEW</b>	<b>1</b>	1.315	33.4	1.097	27.9	0.109	2.77	1.405	1.814	70	2065	2360	2459	11.4
	1¼	1.660	42.2	1.442	36.6	0.109	2.77	1.807	2.514	61	2315	2645	2756	7.3
	1½	1.900	48.3	1.682	42.7	0.109	2.77	2.087	3.049	61	2673	3055	3183	5.8
	2	2.375	60.3	2.157	54.8	0.109	2.77	2.640	4.222	37	2051	2344	2442	4.7
	2½	2.875	73.0	2.635	66.9	0.120	3.05	3.354	5.895	30	2226	2544	2651	3.5
	3	3.500	88.9	3.260	82.8	0.120	3.05	4.336	7.949	19	1730	1977	2060	2.6
	4	4.500	114.3	4.260	108.2	0.120	3.05	5.619	11.789	19	2242	2562	2669	1.6
	5	5.563	141.3	5.295	134.5	0.134	3.40	7.780	17.309	13	2124	2427	2529	1.5
	6	6.625	168.3	6.357	161.5	0.134	3.40	9.298	23.038	10	1953	2232	2325	1.0
	8	8.625	219.1	8.249	209.5	0.188	4.78	16.960	40.086	7	2493	2849	2968	2.1

\* Calculated using Standard UL CRR formula, UL Fire Protection Directory, Category VIZY. The CRR is a ratio value used to measure the ability of a pipe to withstand corrosion. Threaded Schedule 40 steel pipe is used as the benchmark (value of 1.0).

**Wheatland has been leading the way in pipe manufacturing for over 100 years. Learn more at [wheatland.com/fire-sprinkler-pipe](http://wheatland.com/fire-sprinkler-pipe)**

WFS-052820