



NEW SIZE: 10 NPS

HIGH QUALITY HIGH PERFORMANCE

Get Schedule 10 Fire Sprinkler Pipe in All the Sizes You Need

Wheatland's Schedule 10

- ✓ 100% steel
- ✓ No special prep before painting
- ✓ Hot-dip galvanized or black finish
- ✓ ASTM A135, Type E, Grade A
- ✓ NFPA® 13

Wheatland Tube's Schedule 10 sprinkler pipe consistently demonstrates superior performance. Our proprietary mill coating outlasts and outperforms standard lacquer-coated pipe, and our proprietary MIC SHIELD™ antimicrobial coating limits corrosion from microbes. Our newest size, 10 NPS, is the only FM Approved Schedule 10 pipe at this size.



SCHEDULE 10 WEIGHTS AND DIMENSIONS

NPS	NOMINAL OD		NOMINAL ID		NOMINAL WALL		WT./FT.			WT./LIFT	WT./LIFT	WT./LIFT	UL CRR*
	in.	mm	in.	mm	in.	mm	WT./FT.	H ₂ O FILLED	PCS./LIFT	21'	24'	25'	
1	1.315	33.4	1.097	27.9	0.109	2.77	1.405	1.814	70	2065	2360	2459	11.4
1¼	1.660	42.2	1.442	36.6	0.109	2.77	1.807	2.514	61	2315	2645	2756	7.3
1½	1.900	48.3	1.682	42.7	0.109	2.77	2.087	3.049	61	2673	3055	3183	5.8
2	2.375	60.3	2.157	54.8	0.109	2.77	2.640	4.222	37	2051	2344	2442	4.7
2½	2.875	73.0	2.635	66.9	0.120	3.05	3.354	5.895	30	2226	2544	2651	3.5
3	3.500	88.9	3.260	82.8	0.120	3.05	4.336	7.949	19	1730	1977	2060	2.6
4	4.500	114.3	4.260	108.2	0.120	3.05	5.619	11.789	19	2242	2562	2669	1.6
5	5.563	141.3	5.295	134.5	0.134	3.40	7.780	17.309	13	2124	2427	2529	1.5
6	6.625	168.3	6.357	161.5	0.134	3.40	9.298	23.038	10	1953	2232	2325	1.0
8	8.625	219.1	8.249	209.5	0.188	4.78	16.960	40.086	7	2493	2849	2968	1.7
NEW 10**	10.750	273.0	10.374	263.5	0.188	4.78	21.230	57.803	2	892	1019	1062	—

* Calculated using Standard UL® CRR formula, UL Fire Protection Directory, Category VIZY. The CRR is a ratio value used to measure the ability of a pipe to withstand corrosion. Threaded Schedule 40 steel pipe is used as the benchmark (value of 1.0).

** 10 NPS Schedule 10 is FM Approved but not UL Listed.

Wheatland has been leading the way in pipe manufacturing for over 100 years. Learn more at wheatland.com/fire-sprinkler-pipe

WFS-072021